




MARLBORO TOWNSHIP FIRE BUREAU

1979 Township Drive

Marlboro, New Jersey 07746

Office: 732-536-0200 Ext 1802 – Fax: 732-536-9799



To: Marlboro Township Zoning Board

From: Chris Weltner, Fire Official

Re: Z.B. #19-6698; B 175 L 4, 5, 6; Bubbleworks Auto Spa

Date: February 13, 2020

A-22

Requirements:

1. Install and maintain approved fire lanes per Fire Bureau specifications for the rear of the existing building, access from the "short term wipe down area". Submit a separate plan/diagram to the Fire Bureau for approval prior to marking and signage installation. 503.3

Recommendations:

1. No combustible mulch or landscaping within three feet of the building.

Submit any updates to the plan for an additional review.